



FOR IMMEDIATE RELEASE

Contact: Derrick Boone (336) 883-3215

WASTEWATER SPILL NOTIFICATION

HIGH POINT, N.C. (December 31, 2018) – On December 31, 2018, the City of High Point had a wastewater spill of an estimated 4,000 gallons at 5875 Riverdale Drive, the Riverdale Pump Station. Of this total, 4,000 gallons reached the waters of the state. The untreated wastewater spilled into Randleman Lake leading to Deep River. The wastewater spill, which occurred at 11 a.m., was determined to be caused by debris in an air release valve. The Division of Water Quality was notified of the event on December 31, 2018 and is reviewing the matter. For additional information or questions residents should contact the Public Services Department at (336) 883-3215.

House Bill-1160, which the General Assembly enacted in July 1999, requires that municipalities, animal operations, industries and others who operate waste handling systems issue a news release when a waste spill of 1,000 gallons or more reaches surface waters. This notice was sent in accordance with that regulation.

The City of High Point aims to serve as the catalyst for bringing together the community's human, economic and civic resources for the purpose of creating the single most livable, safe and prosperous community in America. For more information on the City, visit www.highpointnc.gov.

###