



NOTES:

- A. THE CITY SERVICE LATERAL SHALL EXTEND PERPENDICULAR FROM THE WATER MAIN TO THE METER SETTER AND MAINTAIN THE SAME COVER AS REQUIRED FOR THE WATER MAIN. THE ONLY EXCEPTION IS IN A CUL-DE-SAC. IN THIS CASE, ONE HORIZONTAL BEND WILL BE ALLOWED. HOWEVER, THE BEND MUST BE FIELD LOCATED AND SHOWN ON THE AS-BUILTS.
- B. ALL WATER TAPS SHALL BE WET TAPS.
- C. NO KINKS ALLOWED IN THE SERVICE. ANY KINKED OR DAMAGED TUBING SHALL BE REMOVED AND REPLACED.

D. APPROVED CORPORATIONS:

- 3/4": -MUELLER 300 BALL CORPORATION VALVE B-25008N SERIES
- A.Y. MCDONALD BRASS 74701BT-3/4"
- FORD FB1000-3GNL
- 1": -MUELLER 300 BALL CORPORATION VALVE B-25008N SERIES
- A.Y. MCDONALD BRASS 74701BT-1"
- FORD FB1000-4GNL

CITY OF HIGH POINT
 NORTH CAROLINA
 ENGINEERING SERVICES DEPARTMENT
 APPROVED FEBRUARY 1, 2007
 BSK
 DIRECTOR

ISSUED 02-01-07	
REVISIONS	
9-14-10	
2-6-14	

STANDARD DRAWING FOR
 3/4" AND 1" SERVICE LINE INSTALLATION (REHAB.)
 FOR REHABILITATION OF 3/4" AND 1" WATER SERVICES

.75_1INST.DWG
 210.00
 SHEET 1 OF 1