



NOTES:

- THE 6' DIAMETER MANHOLE SHALL MEET OR EXCEED ASTM C-478 AND AASHTO M199 SPECIFICATIONS.
- THE MANHOLE LID SHALL BE DESIGNED FOR HS20 LOADING
- THE RING & COVER SHALL MEET CITY STD. NO. 307.00.
- THE BUTTERFLY VALVE AND THE VALVE ACTUATOR WILL BE SPECIFIED BY THE ENGINEER.

12" MIN. #57 STONE

SECTION VIEW

CITY OF HIGH POINT
NORTH CAROLINA
ENGINEERING SERVICES DEPARTMENT

ISSUED 02-01-07
REVISIONS

APPROVED FEBRUARY 4, 2007
DIRECTOR

STANDARD DRAWING FOR

BUTTERFLY VALVE WITH MANHOLE

FOR (16" - 24") WATER MAIN

BUFLY.DWG

243.00

SHEET 1 OF 1