



NOTES:

- A. THE CARRIER PIPE SUPPORTS SHALL BE MADE OF STRUCTURAL STEEL LOW CARBON HOT ROLLED FLAT PLATE ACCORDING TO ASTM A 36/A.
- B. THE CARRIER PIPE SUPPORTS SHALL BE MANUFACTURED BY SPIDER MANUFACTURING, INC. OR AN APPROVED EQUAL.
- C. 4" - 16" CARRIER PIPE REQUIRES TWO "SPIDER" SUPPORTS PER SECTION OF PIPE.
- D. 18" - 36" CARRIER PIPE REQUIRES THREE "SPIDER" SUPPORTS PER SECTION OF PIPE.
- E. 18" AND LARGER CARRIER PIPE SUPPORTS ARE MANUFACTURED AS TWO-PIECE COMPONENTS.
- F. INSULATING LINER SHALL BE EPDM NON-CONDUCTIVE RUBBER 3/16" ± 1/16" THICKNESS (ASTM D-2000 75E).

CITY OF HIGH POINT
 NORTH CAROLINA
 ENGINEERING SERVICES DEPARTMENT
 APPROVED: FEBRUARY 4, 2007
 BSK
 DIRECTOR

ISSUED	REVISIONS
02-01-07	

STANDARD DRAWING FOR
SPIDER SUPPORT
 FOR DUCTILE IRON PIPE INSTALLED IN STEEL ENCASEMENT PIPE

SPIDER.DWG
234.00
 SHEET 1 OF 1