



- NOTES:
1. ENSURE THAT DRAINAGE AREAS DO NOT EXCEED 1 ACRE PER INLET.
 2. THE MAXIMUM SPACING FOR POSTS IS 4 FEET.
 3. THE POSTS SHALL BE 1.25 LB/LF STEEL WITH A MINIMUM LENGTH OF 5 FEET.
 4. WOODEN POSTS NOT ALLOWED.
 5. THIS PRACTICE MUST NOT BE USED NEAR THE EDGE OF FILL MATERIAL AND MUST NOT DIVERT WATER OVER CUT OR FILL SLOPES.

CITY OF HIGH POINT
 NORTH CAROLINA
 ENGINEERING SERVICES DEPARTMENT
 APPROVED... FEBRUARY 17, 2009
 BSK
 DIRECTOR

ISSUED 2-17-09

REVISIONS

STANDARD DRAWING FOR
 WIRE AND STONE INLET PROTECTION
 FOR STORM DRAIN INLETS

INLPRO WS.DWG
 608.00
 SHEET 1 OF 1